

**ADDENDUM NO. 1
TO
THE CONTRACT DOCUMENTS FOR EDGEWOOD, 3rd & 4th AVENUES
PAVEMENT REHABILITATION**

BID OPENING: MONDAY MAY 6, 2019 – 11:00 AM

To All Plan Holders:

The following changes, additions and/or deletions are being made and are hereby a part of the contract documents for Edgewood, 3rd & 4th Avenues Pavement Rehabilitation, as fully and completely as if same were fully set forth therein:

A. Special Provisions, 1st Page

1. **GENERAL**, 5th Bullet point, starting with “• Williams (3rd to 5th)”.
REVISE to state: **Localized curb and gutter replacement as determined (est. 120 L.F.). Mill 2” surface curb to curb with full depth mill adjacent to flange as determined. Base patch flange area under Item No. 5 (Asphalt Patching) with depth to be determined (2 1/2” minimum). Pave 2” surface paid under Item No. 4.**

B. Project Specifications, Page 2

1. **ITEM NO. 3 & 4 – ASPHALT BINDER AND ASPHALT SURFACE**
First Sentence – Revise “1 3/4” surface upper level 5LT 58-28S” to “**1 3/4” or 2” surface upper level shall be 5MT 58-28S.**
2. Add the following after the 1st paragraph:
A rubber tire compactor (pneumatic roller) shall be used on all MT pavement designs to achieve uniform compaction.

C. Proposal, Page 1

1. **REVISE ITEM NO. 4 – Asphalt Surface (1 3/4” or 2”)**
from QTY. 725 TON to **1025 TON**
2. **REVISE ITEM NO. 7 – Asphalt Milling (2”)**
from QTY. 470 S.Y. to **2250 S.Y.**

This addendum is hereby made a part of the contract documents.

All bidders shall acknowledge receipt and acceptance of this Addendum No. 1 consisting of one (2) pages, by signing in the space provided and submitting the signed addendum with the bid.


Bids submitted without this addendum may be considered non-responsive. Dated this 2nd day of May, 2019.

CITY OF SOUTH MILWAUKEE

Receipt acknowledged and conditions agreed to
this _____ day of _____

Bidder

By



Kyle Vandercar, P.E.
City Engineer